

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7167-1459:110 Page 1 of 1

**CATEGORY:** Control Unit (Household)

**LISTEE:** Sentrol Inc., 1510 Tate Blvd., S.E., Hickory, NC 28603  
Contact: Jeff Jacumin (704) 322-2333

**DESIGN:** Models ZX200 and ZX210 household fire alarm control units. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

ZX200, ZX210	Control Unit
ZXLED8	Keypad
ZXSSD	Keypad
ZXLCD	LCD Keypad
ZXVFD	VFD Keypad
ZXODM	Output Driver Module
EX1414	Enclosure
TC-1100	Attack Resistant Enclosure
MPI-266	Battery Cut-off Module
MPI-267	Power Disconnect Module
MPI-268	Earth Ground Fault Detector

**RATING:** Primary: 16.5 VAC, 35 VA; Secondary: 12 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 4 minutes of alarm as required by code.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as residential fire alarm control units for use with separately listed compatible initiating and indicating signaling devices. These control units can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1993 Edition.

**NOTE:**

1. Burglary and other non-fire functions were not examined. Refer to listee's datasheet for compatible non-fire devices.
2. **Fire Alarm Verification Feature** (delay of fire alarm) is **NOT** approving for residential use in California. This feature must not be programmed into the unit.

03-20-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 17, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy  
Program Manager